


LEGENDA:



- Convector electric montaj perete ,1000-2500 W, 230V, IP 24
- Convector electric montaj perete ,600 W, 230V, IP 65
- Aparat aer conditionat monosplit 9000 BTU;
1 unitate interioara, UI ;
1 unitate exterioara, UE ;
Capacitate racire : 9000 BTU;
Capacitate incalzire : 10000 BTU;
Tensiune alimentare : 230V/50 Hz;
Agent frigorific : R32;
SEER : 6,2;
SCOP: 4,0;

CLASA DE IMPORTANTA III- conform P100-1/2013
CATEGORIA DE IMPORTANTA C- conform H.G. nr. 766/1997
GRADUL DE REZISTENTA LA FOC III- conform NP118/1999;

| | | | | | |
|-------------------------------|--|-----------|---------|---|------------------------|
| VERIFICATOR EXPERT | NUME | SEMNATURA | CERINTA | REFERAT/ EXPERTIZA/ NR./ DATA | |
| PROIECTANT GENERAL | S.C. STRUCT-EL PROIECT S.R.L. BUDACU DE JOS | | | Beneficiar: U.A.T. COMUNA TELCIU SAT TELCIU, NR. 744 B | Proiect nr. 23/2025 |
| PROIECTANT DE SPECIALITATE | S.C. PLANEX LINE S.R.L. FELDRU | | | JUD. BISTRITA-NASAUD Titlu proiect: CONSTRUIRE CAPELA MORTUARA COM. TELCIU, SAT BICHIGIU, FN. JUD. BISTRITA-NASAUD | Faza DTAC+ PT |
| SPECIFICATIE | NUME | SEMNATURA | Scara | Titlu plansa PLAN PARTER instalatii termice | Plansa nr. ITO1 |
| SEF PROIECT | arh.DEMIAN DAIANA | | 1: 50 | | |
| PROIECTAT | ing.GALAN VIORICA | | Data | | |
| INTOCMIT | ing.GALAN VIORICA | | 07.2025 | | |